



Figure 4-12. Sampling port and drainfield.

2. Within 30 days of completing the installation, the property owner shall provide certification to the regulatory authority, from their O&M entity, that the system has been installed and is operating in accordance with the manufacturer's recommendations (IDAPA 58.01.03.005.15).
 - a. A statement requiring the submission of the installation verification form described above shall be written on the face of the subsurface sewage disposal permit.
 - b. The regulatory authority shall not finalize the subsurface sewage disposal permit until the certification of proper installation and operation is received and includes information on the manufacturer, product, model number, and serial number of the ETPS unit installed.