

Clean Water State Revolving Fund Green Project Reserve

- Interim -



City of Ashton Wastewater Facility Upgrade Project

SRF Loan #WW1701 (pop. 1084)

\$4,900,000

Interim Green Project Reserve Justification

Categorical GPR Documentation

1. INSTALL NEW ENERGY-EFFICIENT AERATORS AND MIXERS IN AERATED TREATMENT PONDS (Energy Efficiency). Business Case per GPR 3.2-2: *Projects that achieve a 20% reduction in energy consumption are categorically eligible for GPR.* (\$170,414).
2. INSTALLS ENERGY-EFFICIENT EFFLUENT TRANSFER PUMPS IN NEW EFFLUENT PUMP STATION (Energy Efficiency). Business Case per GPR 3.2-2: *Projects that achieve a 20% reduction in energy consumption are categorically eligible for GPR.* (\$10,000).

1. NEW ENERGY-EFFICIENT AERATORS & MIXERS

Summary

- A winter storage pond will be constructed and treated wastewater will land applied during summer months to eliminate a stream discharge and to avoid permitting issues.
- Total Loan amount = \$4,900,000
- Estimated Categorical energy efficient (green) portion of loan = 3.5% (\$170,414)
- Annual Energy savings = 72%



Background

- A four-cell lagoon provides secondary treatment through four (4) 5 HP Aeromix Tornado aspirating aerators in Lagoon No. 1 and two (2) more aerators in Lagoon No. 2.
- The aerators are expensive to maintain. Common repairs include replacement of the hollow shaft and lower bearing at a cost of about \$3,000 every two years. Motors have to be replaced every three years at \$450 each.
- The aerators are also expensive to operate, being powered by standard efficiency motors.
- There are short-circuiting issues due to poor mixing.

Energy Efficiency Improvements

EXISTING SYSTEM

- Currently six (6) 5 HP aerators with standard efficiency motors are used for mixing and oxygen transfer = 30 HP total. The aerators run for an average of 24 hours daily; therefore the energy consumed on an annual basis by the current system = $(24 \text{ hrs/da})(365 \text{ da/yr})(30 \text{ HP})(.7457 \text{ kW/HP}) = 195,970 \text{ kWh/yr}$.

BASELINE STANDARD PRACTICE (BSP)

- The Baseline Standard Practice design is four 5 HP aerators in Lagoon 1, two 5 HP aerators in Lagoon 2, and two 5 HP aerators in Lagoon 4 for mixing and oxygen transfer = 40 HP total.
- The aerators run year-round, 24 hours per day, therefore the energy consumed on an annual basis for the BSP design = $(24 \text{ hrs/da})(365 \text{ da/yr})(40 \text{ HP})(.7457 \text{ kW/HP}) = 261,293 \text{ kWh/yr}$.
- The cost of the aeration equipment for the BSP design is $(8)(\$14,383) = \$115,064$.

GPR ALTERNATIVE

- The GPR alternative replaces the BSP design with five (5) new 5 HP aerators with energy-efficient motors, and three (3) fractional HP mixers (26 HP total). The new aerators will run for 24 hours for five months during the winter, November through March. Therefore the energy consumed on an annual basis by the proposed aerators = $(24 \text{ hrs/da})(151 \text{ da/yr})(25 \text{ HP})(.7457 \text{ kW/HP}) = 67,560 \text{ kWh/yr}$.
- The fractional HP mixers (1/3 HP each) will run year-round, 24 hours per day. The energy consumed on an annual basis by the proposed mixers = $(24 \text{ hrs/da})(365 \text{ da/yr})(1 \text{ HP})(0.7457 \text{ kW/HP}) = 6,532 \text{ kWh/yr}$.
- Therefore, the total power requirement for the GPR Alternative = Aerators + Mixers = $67,560 \text{ kWh/yr} + 6,532 \text{ kWh/yr} = 74,092 \text{ kWh/year}$
- The cost of the aeration equipment for the GPR Alternative is $(5)(\$14,383) + (3)(\$32,833) = \$170,415$.

GPR SAVINGS VS. BSP

- The annual power savings = total power use for the BSP design vs the GPR alternative. The calculated power savings = $261,293 - 74,092 = 187,201 \text{ kWh/year}$.
- The annual cost savings is = annual power savings $(187,201 \text{ kWh/year})(\$0.0951/\text{kWh}) = \$17,803/\text{yr}$.
- The payback period for the GPR Alternative is the cost difference between the BSP & the GPR Alternative \div \$/year savings = 3.1 years.



Conclusion

- Using premium energy efficient aerators and reducing the number of aerators by using fractional HP mixers, the City reduces their power needs by approximately 187,201 kW-hr per year and annual power costs by approximately \$17,803 each year from the BSP design. This represents a 72% overall savings per year in energy and costs.
- **GPR Alternative Costs:**
 - Energy efficient aerators = (5)(\$14,383) = \$71,915
 - Fractional HP mixers = (3)(\$32,833) = \$98,499
 - Total = \$170,414**
- **GPR Justification:** Categorically GPR per 3.2-2: *Projects that achieve a 20% reduction in energy consumption are categorically eligible for GPR¹.*

¹ Attachment 2. EPA Guidance for Determining GPR Eligibility for FY12 SRF Projects

2. HIGH EFFICIENCY PUMPS

Summary

- A pond will be constructed to store treated effluent in the winter and land applied as irrigation during the summer months. This will eliminate the existing stream discharge and avoid permitting issues.
- Total Loan amount = \$4,900,000
- Estimated Categorical energy efficient (green) portion of loan = 0.2% (\$10,000)
- Annual Energy savings = 26%

Background

- A new pump station will be installed to transfer treated effluent from the treatment lagoons to the new winter effluent storage pond.

Results

- GPR-eligible items are the high efficiency pumps to transfer treated wastewater from the lagoons to the new winter effluent storage pond.

Effluent Transfer Pumps

- The effluent pump station consists of two (2) pumps and one spare to pump the design maximum day flow of 0.118 MGD from the lagoons to the winter storage pond.
- The Baseline Standard Practice (BSP) is a pump with an efficiency = 58.2%; energy usage = 3,311 kWh/year.
- The cost of the BSP pumps is 3 @ \$5,000/ea = \$15,000
- The GPR Alternative pumps will have an efficiency = 78.2%; energy usage = 2,455 kWh/year.
- The cost of the GPR pumps is 3 @ \$6,667/ea = \$20,000
- Energy Reduction = BSP pumps 3,311 kWh/yr – GPR pumps 2,455 kWh/yr = 856 kWh/yr = 26% reduction



Conclusion

- Using high efficiency pumps instead of pumps with efficiencies more common to wastewater pumps will save the City 855 kWh/yr or a 26% reduction in energy demand.
- **GPR Costs:**
GPR pumps = 2 duty pumps @ \$5,000 ea = \$10,000
- **GPR Justification:** Categorically GPR per 3.2-2: *Projects that achieve a 20% reduction in energy consumption are categorically eligible for GPR².*

² Attachment 2. EPA Guidance for Determining GPR Eligibility for FY12 SRF Projects