Impressed Current Log Goes Here ☑

Once every 2 months, go to your impressed current rectifier and fill in the following information. If you discover the rectifier has no sign of power (no volts and no amps), your UST system may not be protected from corrosion. If this occurs, contact a service provider and have the problem promptly investigated.

Date	Power on	Volts	Amps	Initials

In the event you suspect a problem (no volts or amps reading or the levels are significantly fluctuating), call a service provider for further assistance.